



United States Environmental Protection Agency
Washington, D. C. 20460

Form Approved
OMB No. 2040-0003

M/035/015

Section A: National Data System Coding

Transaction Code 1 <u>N</u> 2 <u>I</u>	NPDES 3 <u>1111010101015111</u>	Yr/Mo/Day 11 <u>12</u> 12 <u>12</u> 17 <u>01</u> 7	Inspection 17 <u>18</u> 18 <u>18</u>	Inspector 19 <u>15</u>	Fac Type 20 <u>12</u>
Remarks 21 <u> </u> 66					
Reserved 67 <u> </u> 69	Facility Evaluation Rating 70 <u>15</u>	BI 71 <u>12</u>	QA 72 <u>11</u>	Reserved 73 <u> </u> 74	Reserved 75 <u> </u> 80

Section B: Facility Data

Name and Location of Facility Inspected KENNECOTT UTAH COPPER MINE SALT LAKE COUNTY	Entry Time 10:00	Permit Effective Date FEBRUARY 5, 1995
	Exit Time/Date NOON / JULY 9, 1998	Permit Expiration Date JANUARY 31, 2000
Name(s) of On-Site Representative(s) RIC JONES	Title(s)	Phone No(s) (801) 569-7910
Name, Address of Responsible Official W. R. WILLIAMS MAGNA, UTAH	Title DIRECTOR, HEALTH SAFETY & ENVIRONMENTAL QUALITY	Contacted NO
	Phone No. (801) 252-3110	

RECEIVED
AUG 03 1998
DIV. OF OIL, GAS & MINING

Section C: Areas Evaluated During Inspection

(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)

N	Permit	N	Flow Measurement	N	Pretreatment	S	Operations & Maintenance
N	Records/Reports	N	Laboratory	N	Compliance Schedules	N	Sludge Disposal
S	Facility Site Review	S	Effluent/Receiving Water	N	Self-Monitoring Program		Other:

Section D: Summary of Findings/Comments (Attach additional sheets if necessary)

THERE WAS NO DISCHARGE AT OUTFALLS 001, 002, AND 007.

THE EXPANSION OF THE SANITARY TREATMENT PLANT WAS STILL IN PROGRESS. THE OUTFALL IS SENT TO THE OLD TREATMENT PLANT AND HENCE TO THE TAILINGS IMPOUNDMENT. SO THERE IS NO DISCHARGE.

ADAMSON SPRING BY THE RECYCLE PUMP HOUSE AT THE SOUTHEAST CORNER OF THE EXISTING IMPOUNDMENT HAS BEEN TESTED TO SEE IF IT CAN BE DISCHARGED. KENNECOTT WILL SUBMIT THE REQUEST LATER. THIS WILL BE ROUTED TO THE SALT LAKE CANAL WHICH FLOWS TO THE C-7 DITCH.

TWO SEEPS FROM THE OLD IMPOUNDMENT ARE NOW CONTAINED ON KENNECOTT PROPERTY.

Name(s) and Signature(s) of Inspector(s) STEVEN MCNEAL <i>Steven McNeal</i>	Agency/Office/Telephone EQ/ WATER QUALITY/ (801) 538-6075	Date JULY 30, 1998
Signature of Reviewer DONALD A. HILDEN <i>Donald A. Hilden</i>	Agency/Office EQ/ WATER QUALITY	Date 7/30/98
Regulatory Office Use Only		
Action Taken	Date	Compliance Status Noncompliance Compliance